

NOTE: VENEER & AIR/
MOISTURE BARRIER NOT
SHOWN

GROUT & VERTICAL
REINFORCING AS
REQUIRED

HORIZONTAL JOINT
REINFORCEMENT

LAP VERTICAL BAR
SPLICE ABOVE
PLANK LEVEL

PRECAST CONCRETE
PLANK

TOPPING IF REQ'D

2'-0" HORIZ. x 2'-0"
VERT. #4 DOWELS
AND GROUT AT
PLANK KEYWAYS –
SEE DETAIL 20.P02

GROUT PLANK
SOLID AT BEARING

SOLID CMU

BOND BEAM W/
(2) #5, CONT, OR
AS REQ'D

3" MIN. BEARING &
BEARING STRIP

PLANK AT BEARING WALL

INTERMEDIATE ELEVATION

DETAIL 02.120.0751

REV. 11/25/08

International Masonry Institute



800-IMI-0988 www.imiweb.org

© 2011 INTERNATIONAL MASONRY INSTITUTE